

| Year/ Ref No | Date of application | Name/Address of premises | Type of premises e.g. School, care home | Local Authority | Standard and Reason for application | Rationale for Approval/Refusal | Granted/Not granted |
|--------------|---------------------|--------------------------|---|-----------------|-------------------------------------|--------------------------------|---------------------|
|--------------|---------------------|--------------------------|---|-----------------|-------------------------------------|--------------------------------|---------------------|

2010 - NONE

2011

| | | | | | | | |
|--------|------------|--|--------|---|---|---|---------|
| 2011/1 | 05/07/2011 | Temporary classroom accommodation for Methilhill Primary School In the grounds of Buckhaven High School Methilhaven Road Buckhaven Leven K78 1HL | School | [redacted] Building Standards Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Eight temporary detached classroom buildings total approximately 1152 m ² are to allow decant to facilitate roof works to the existing school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2011/2 | 16/08/2011 | Extension Anderson High School Knab Road Lerwick Shetland ZE1 0JH | School | Shetland Islands Council [redacted] Building Standards Manager Planning Infrastructure Services Department Grantfield Lerwick Shetland ZE1 0NT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The enlarged social space extension is approximately 70 m ² . The additional cost of sprinklers is considered disproportionate to construction cost. | Granted |
| 2011/3 | 22/08/2011 | Temporary classrooms Lochardil Primary School Lochardil Road Inverness IV2 4LB | School | The Highland Council [redacted] Building Standards Manager Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 Additional accommodation to main school building. | Main building not sprinklered. One temporary detached classroom building total approximately 139 m ² is to allow decant to facilitate the demolition and rebuild of existing classrooms. Considered unreasonable in the circumstances to require sprinklers. | Granted |

| | | | | | | | |
|------------|------------|--|--------|--|--|--|---------|
| 2011/4 | 16/09/2011 | Abernethy Primary School 78 Main Street Abernethy PH2 9LA | School | [redacted] Building Standards Manager Perth & Kinross Council The Environment Service Pullar House 35 Kinnoull Street Perth PH1 5GD | 2.15 Additional accommodation to main school building. | The main building is not sprinklered. The accommodation is needed to decant the whole school to facilitate the alteration and extension to the existing school building. The temporary accommodation comprises two detached buildings. One building has a ground floor of approximately 267 m ² with a first floor of approximately 148 m ² . The other building has ground floor of approximately 327 m ² with first floor having the same footprint. | Granted |
| 2011/4 - A | 03/02/2012 | Amended layout from previous agreed relaxation (ref 2011/4) | School | [redacted] Building Standards Manager Perth & Kinross Council The Environment Service Pullar House 35 Kinnoull Street Perth PH1 5GD | 2.15 Additional accommodation to main school building | The main building is not sprinklered. The accommodation is needed to decant the whole school to facilitate the alteration and extension to the existing school building. The temporary classroom and ancillary accommodation comprises two detached buildings that have a total floor area of approximately 1138 m ² ; and a single storey detached toilet block. | Granted |
| 2011/5 | 16/11/2011 | Taynuilt Primary School Taynuilt Argyll PA31 8RT | School | [redacted] Building Standards Manager Argyll & Bute Council Development Services Kilmory Lochgilphead Argyll PA31 8RT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The classroom extension is approximately 67 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2011/6 | 28/11/2011 | The Edinburgh Academy Junior School 10 Arboretum Place Edinburgh EH3 5PL | School | [redacted] Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The classroom block extension is approximately 237 m ² . The additional cost of sprinklers is considered disproportionate to construction cost. | Granted |

| | | | | | | | |
|--------|------------|---|--------|---|--|--|---|
| 2012/1 | 24/01/2012 | Prospectbank Special School 81 Restalrig Road Edinburgh EH6 8BQ | School | [redacted] Acting Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. A permanent detached classroom building approximately 29 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |
| 2012/2 | 02/03/2012 | The Edinburgh Academy 10 Arboretum Place Edinburgh EH3 5PL | School | [redacted] Acting Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Two temporary detached classroom buildings total approximately 400 m ² are to allow decant to facilitate the completion of extension to the main school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/3 | 02/03/2012 | Castlepark Primary School Carron place Castlepark Irvine Ayrshire KA12 9LQ | School | [redacted] Chief Building Standards Officer North Ayrshire Council Corporate Services Cunninghame House Irvine KA12 8EE | 2.15 Additional accommodation to main school building | Main building not sprinklered. Application for five extensions. Three of these are approximately 78 m ² , 51 m ² and 153 m ² . The remaining two extensions are a community nursery approximately 810 m ² and, classrooms/ancillary area approximately 423 m ² . In consideration of sustainability, costs, fire risk and community impact, there is no reason to justify relaxation for the two larger extensions. | Granted for three smaller extensions. Not granted for two larger extensions. |
| 2012/5 | 07/03/2012 | Morrison's Academy Ferntower Road Crieff Perthshire PH7 2AB | School | [redacted] Building Standards Manager Perth & Kinross Council The Environment Service Pullar House 35 Kinnoull Street Perth PH1 5GD | 2.15 Additional accommodation to main school building. | Main building not sprinklered. A permanent detached nursery building approximately 295 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |

| | | | | | | | |
|---------|------------|--|--------|---|--|--|---------|
| 2012/7 | 04/04/2012 | Kingussie High School Ruthven Road Kingussie PH21 1ES | School | The Highland Council [redacted] Building Standards Manager Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Two temporary detached buildings of approximately 161 m ² and 323 m ² are to allow decant to facilitate and alteration and refurbishment of the school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/8 | 09/04/2012 | Kelty Primary School 96-102 Main Street Fife KY4 0AQ | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The temporary detached building of approximately 168 m ² is to allow decant during the construction of a new extension for the school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/9 | 03/05/2012 | St Lukes Primary School Pennyburn Road Kilwinning KA13 6LF | School | [redacted] Chief Building Standards Officer North Ayrshire Council Corporate Services Cunninghame House Irvine KA12 8EE | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The classroom extension and ancillary accommodation is approximately 80 m ² . The additional cost of sprinklers is disproportionate to construction. | Granted |
| 2012/10 | 29/05/2012 | Tayport Primary School Queen Street Tayport Fife DD6 9NS | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The multi-use hall extension and ancillary accommodation is approximately 397 m ² ; plus a lower ground level plant room of 100 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |

| | | | | | | | |
|---------|------------|---|--------|--|--|---|---------|
| 2012/11 | 04/05/2012 | Gartcosh Primary School Lochend Road Gartcosh Glasgow G69 8AB | School | [redacted] Business Manager Business Development & Building Standards North Lanarkshire Council Environmental Services Building Standards Municipal Buildings Kildonan Street Coatbridge ML5 3LN | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The temporary detached building of approximately of 194 m ² is to cater for an increased school roll. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/12 | 24/08/2012 | Erskine Stewart's Melville School Queensway House 1 Queensferry Terrace Edinburgh EH4 3ER | School | [redacted] Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building | The existing buildings are not sprinklered. Due alterations to the subject building an additional escape stair extension of approximately 67 m ² is required. The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/13 | 07/08/2012 | St Anthony's Primary School 87 South Street Armadale EH48 3EU | School | [redacted] Building Standards County Buildings High Street Linlithgow EH49 7EZ | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The facility for changing and showering extension (to the existing detached sports hall) is approximately 413 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/14 | 09/08/2012 | Cargilfield School 37 Barnton Avenue West Edinburgh EH4 6DF | School | [redacted] Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The facility for changing and showering extension (to the existing detached sports hall) is approximately 413 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/15 | 02/11/2012 | Park Primary School Kerrera Terrace Oban Argyll PA34 5AU | School | [redacted] Building Standards Manager Argyll & Bute Council Development Services Kilmory Lochgilphead Argyll PA31 8RT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The main indoor and outdoor play areas, and ancillary accommodation extension is approximately 440 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |

| | | | | | | | |
|---------|------------|--|--------|--|---|--|---------|
| 2012/17 | 06/11/2012 | Extension to the studio theatre Gordonstoun School Duffus Elgin IV30 5RF | School | [redacted] Building Standards Manager Building Standards Council Offices High Street Elgin IV30 1BX | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The Drama, dance teaching and ancillary accommodation extension is approximately 440 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/19 | 26/11/2012 | Ballachulish Primary School Gorsten Road Ballachulish PH49 4JQ | School | [redacted] Building Standards Manager The Highland Council Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 To allow additional school accommodation to be constructed (expanding rolls). | Main building not sprinklered. The temporary detached building of approximately 59 m ² is to allow decant during the construction of new accommodation for the school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/20 | 27/11/2012 | St Martins Primary School Place of Bonhill Renton G82 4QB | School | [redacted] Team leader West Dunbartonshire Council Planning and Building Standards Council Offices Rosebery Place Clydebank G81 1TG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The extension comprises a cloakroom space approximately 25 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/21 | 10/12/2012 | Kelty Primary School 96-102 Main Street Fife KY4 0AQ | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Two extensions comprise multi-purpose space and ancillary accommodation approximately 336 m ² a store room. The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/22 | 10/12/2012 | Collydean Primary School Magnus Drive Glenrothes Fife KY7 6TR | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The multi-storey space and ancillary accommodation extension is approximately 240 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |

| | | | | | | | |
|-------------|------------|---|--------|--|--|---|--|
| 2012/23 | 07/12/2012 | Dalgety Bay Primary School St Bridgets Brae Dalgety Bay Fife KY11 9LT | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Forth House Abbotshall Road Kirkcaldy KY1 1RU | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The two storeroom extensions are approximately 25 m ² and 41 m ² . The additional cost of sprinklers is disproportionate to construction cost. | Granted |
| 2012/25 | 07/12/2012 | Castlepark Primary School Carron Place Castlepark Irvine Ayrshire KA12 9LQ | School | [redacted] Chief Building Standards Officer North Ayrshire Council Corporate Services Cunninghame House Irvine KA12 8EE | 2.15 To allow refurbishment of main school building. | Main building not sprinklered. The temporary detached building is approximately 1423 m ² and is to allow decant during the refurbishment of main school building. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2012/26 | 10/12/2012 | Fettes College 2 Carrington Road Edinburgh EH4 1QX | School | [redacted] Property Manager (Building Standards & Contingency Planning) Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to North school building comprises new attached four storey classroom block; and infill extension over courtyard. | Main building not sprinklered. The attached four storey classroom block floor area is approximately 2,800 m ² , and the cost of sprinklers is not disproportions to construction costs. The cost of sprinklers to the courtyard extension 100 m ² is disproportionate to construction cost and therefore dispensation is granted. | Not granted to detached 4 storey classroom block Granted to infill extension |
| 2013 | | | | | | | |
| 2013/2 | 14/01/2013 | Kinnoull Primary School Dundee Road Perth PH2 7EY | School | [redacted] Building Standards Manager Perth & Kinross Council The Environment Service Pullar House 35 Kinnoull Street Perth PH1 5GD | 2.15 Additional accommodation to main school building. And new detached gym. | Main building not sprinklered. The extension is approximately 164 m ² , and detached gym of 131 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |

| | | | | | | | |
|--------|------------|---|--------|--|--|--|---------|
| 2013/3 | 25/01/2013 | Boghall Primary School 33 Elizabeth Drive Boghall Bathgate EH48 1JB | School | [redacted] Building Standards County Buildings High Street Linlithgow EH49 7EZ | 2.15 Additional accommodation to main school building and include a community centre. | Main building not sprinklered. Extension approximately 751.5 m ² . This comprises community centre of 454.2 m ² in separate compartment; and 225.4 m ² for the school use. The additional cost of sprinklers disproportionate the construction cost. | Granted |
| 2013/4 | 29/01/2013 | Hermitage Primary School East Argyll Street Helensburgh Argyll and Bute G84 7EW | School | [redacted] Building Standards Manager Argyll & Bute Council Development Services Kilmory Lochgilphead Argyll PA31 8RT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. A permanent detached building approximately 286 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |
| 2013/5 | 18/02/2013 | Dirleton Primary School Dirleton East Lothian EH39 5HE | School | [redacted] East Lothian Council John Muir House Brewery Park Haddington EH41 5HA | 2.15 Additional accommodation to main school building. (Increased pupil numbers). | Main building not sprinklered. Three extensions are approximately 170.51 m ² , 13.02 m ² and 35.07 m ² . The additional cost of sprinklers to the extensions is disproportionate the construction cost. | Granted |
| 2013/6 | 18/02/2013 | Wardie Primary School 103B Granton Road Edinburgh EH5 3NJ | School | [redacted] Building Standards Group Leader Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building (Increased pupil numbers). | Main building not sprinklered. A permanent detached building approximately 260 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |
| 2013/7 | 18/02/2013 | Trinity Primary School 181 Newhaven Road Edinburgh EH6 4QA | School | [redacted] Building Standards Group Leader Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building (Increased pupil numbers). | Main building not sprinklered. A permanent detached building approximately 410 m ² . The additional cost of sprinklers is disproportionate the construction cost. | Granted |

| | | | | | | | |
|-----------|------------|---|--------|---|---|---|---------|
| 2013/8 | 18/02/2013 | Granton Primary School 59 Boswall Parkway Edinburgh EH5 2DA | School | [redacted] Building Standards Group Leader Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building (Increased pupil numbers). | Main building not sprinklered. A permanent detached building approximately 187 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/9 | 19/02/2013 | Lochaber High School Camaghael Fort William PH33 7ND | School | [redacted] Building Standards Manager The Highland Council Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 To allow additional school accommodation to be constructed. | Main building not sprinklered. The two temporary detached building of 160 m ² and 365 m ² are to allow decant during the construction of new accommodation for the school. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2013/10/A | 01/03/2012 | New Elgin Primary School Bezack Street Moray IV30 6DP | School | [redacted] Building Standards Manager Building Standards Council Offices High Street Elgin IV30 1BX | 2.15 Additional nursery accommodation to main school. | Main building not sprinklered. Extension approximately 204 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/10/B | 01/03/2012 | East End Primary School Institution Road Moray IV30 1RP | School | [redacted] Building Standards Manager Building Standards Council Offices High Street Elgin IV30 1BX | 2.15 Additional nursery accommodation to main school. | Main building not sprinklered. Extension approximately 210 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/11 | 04/03/2012 | Glenlyon Primary School Bridge of Balgie Glenlyon by Aberfeldy PH15 2PP | School | [redacted] Building Standards Manager Perth & Kinross Council The Environment Service Pullar House 35 Kinnoull Street Perth PH1 5GD | 2.15 Additional link corridor to main school building. | Main building not sprinklered. Extension approximately 65.5 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |

| | | | | | | | |
|---------|-------------------------------------|--|--------|---|---|---|---------|
| 2013/12 | 06/03/2013 | Central Primary School Kenneth Street Inverness IV3 5DW | School | [redacted] Building Standards Manager The Highland Council Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 To allow refurbishment of main school building. | Main building not sprinklered. The temporary detached building is approximately 148 m ² and is to allow decant during the refurbishment of main school building. Considered unreasonable in the circumstances to require sprinklers. | Granted |
| 2013/13 | 06/03/2013 - 11/3/12 accepted | Balbardie Primary School 16 Torphican Street Bathgate EH48 4HL | School | [redacted] Building Standards County Buildings High Street Linlithgow EH49 7EZ | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Extension approximately 449 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/16 | 18/04/2013 | Rosewell Primary School 85 Carnethie Street Rosewell Midlothian EH24 9AN | School | [redacted] Building Standards Manager Midlothian Council Fairfield House 8 Lothian Road Dalkeith EH22 3ZN | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Extension approximately 360 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/18 | 17/04/2013 | St Andrews Primary School Toab Orkney KW17 2QU | School | [redacted] Principal Building Standards Officer Orkney Islands Council Department of Development Services Council Offices School Place Kirkwall KW1 1NY | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Extension approximately 65.7 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |

| | | | | | | | |
|---------|------------|---|--|---|--|--|---------|
| 2013/19 | 19/04/2013 | Strontian Primary School Strontian Acharacle PH36 4HZ | School | [redacted] Building Standards Manager The Highland Council Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 Additional accommodation to main school building | Main building not sprinklered. Two extension 11.96 m ² and 25.33 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/23 | 21/05/2013 | | School | [redacted] City Development Planning Division Building Standards Floor 6 Dundee House 50 North Lindsay Street Dundee DD1 1LS | 2.15 Proposed refurbishment of main school building. | Main building not sprinklered. The three temporary buildings total 830 m ² and will allow decant during the refurbishment of main school building. Considered unreasonable in the circumstances to require the temporary building to be sprinklered. | Granted |
| 2013/24 | 28/05/2013 | Lochdonhead Primary School Lochdon Isle of Mull PA64 6AP | School | [redacted] Building Standards Manager Argyll & Bute Council Development Services Kilmory Lochgilphead Argyll PA31 8RT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The extension is 20 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/26 | 04/06/2013 | The City Observatory 38 Calton Hill Edinburgh EH7 5AA | Non- domestic building Temporary gallery | [redacted] Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 3.7 Alterations to building to form toilets. | The temporary gallery is a limited life building. | Granted |

| | | | | | | | |
|---------|------------|--|--------|--|---|---|---------|
| 2013/27 | 04/06/2013 | Bucksburn Primary School Inverurie Road Bucksburn Aberdeen AB21 9LL | School | [redacted] Building Standards Manager Aberdeen City Council Building Standards Planning & Sustainable Development Aberdeen City Council Business Hub 4 Ground Floor North Marischal College Broad Street Aberdeen AB10 1AB | 2.15 Proposed refurbishment of main school building. | Main building not sprinklered. Two detached temporary building of approximately 156 m ² and 830 m ² to allow decant during the refurbishment of main school building. Considered unreasonable in the circumstances to require the temporary building to be sprinklered. | Granted |
| 2013/28 | 04/06/2013 | Ardeer Primary School Clark Street Stevenson Ayrshire KA20 3LZ | School | [redacted] Chief Building Standards Officer North Ayrshire Council Corporate Services Cunninghame House Irvine KA12 8EE | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Two single storey extensions of approximately 42 m ² and 15 m ² are proposed to the existing school building and will provide changing room / toilet accommodation The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/29 | 29/04/2013 | Happyhansel Primary School Walls Shetland ZE2 9PG | School | Shetland Islands Council [redacted] Building Standards Manager Planning, Infrastructure Services Department Grantfield Lerwick Shetland ZE1 0NT | 2.15 Additional accommodation to main school building. | Main building not sprinklered. Extension 123 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |
| 2013/30 | 12/06/2013 | James Gillespie's Primary School James Gillespie's Campus 51 Whitehouse Loan Edinburgh EH9 1DD | School | [redacted] Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 Additional accommodation to main school building. | Main building not sprinklered. The size of the extension is 522 m ² . The additional cost of sprinklers to the extension is disproportionate the construction cost. | Granted |

| | | | | | | | |
|---------|------------|---|--------|--|---|---|---------|
| 2013/31 | 12/06/2013 | James Gillespie's High School James Gillespie's Campus 57 Lauderdale Street Edinburgh EH9 1DD | School | [redacted] Property Manager Building Standards City of Edinburgh Council Waverley Court 4 East Market Street Edinburgh EH8 8BG | 2.15 To provide temporary accommodation so that extension can be made to main school building. | Considered unreasonable in the circumstances to require the temporary detached building to be sprinklered. | Granted |
| 2013/33 | 15/07/2013 | Forthill Primary School Fintry Place Broughty Ferry Dundee DD5 3BE | School | [redacted] City Development Planning Division Building Standards Floor 6 Dundee House 50 North Lindsay Street Dundee DD1 1LS | 2.15 Extension to primary school. | Permanent detached building 186 m ² . The additional cost of sprinklers to the new building is disproportionate to its long term hire cost. | Granted |
| 2013/34 | 24/07/2013 | St Peters Primary School 74 Dunbar Street Aberdeen AB24 3UJ | School | [redacted] Building Standards Manager Aberdeen City Council Building Standards Planning & Sustainable Development Aberdeen City Council Business Hub 4 Ground Floor North Marischal College Broad Street Aberdeen AB10 1AB | 2.15 To provide temporary accommodation for increasing pupil numbers. | The proposed detached temporary building is 155 m ² . The existing school building is 1,471 m ² . The cost of sprinklers is disproportionate to the cost of the temporary building. | Granted |

| | | | | | | | |
|---------|--|--|--------|--|---|--|---------|
| 2013/35 | 24/07/2013 | Woodlands School Regents Walk Aberdeen AB24 1SX | School | [redacted] Building Standards Manager Aberdeen City Council Building Standards Planning & Sustainable Development Aberdeen City Council Business Hub 4 Ground Floor North Marischal College Broad Street Aberdeen AB10 1AB | 2.15 To provide temporary accommodation for increasing pupil numbers. | The proposed detached temporary building is 155 m ² . The existing school building is 1,633 m ² . The cost of sprinklers in disproportionate to the cost of the temporary building. | Granted |
| 2013/36 | 12.813 (date received) 9.9.13 (form date) | Learning Centre Upper Seaview Cornhill Banff Aberdeenshire AB45 2HJ | School | [redacted] Building Standards Manager Aberdeenshire Council Planning & Environmental Services Viewmount Arduthie Road Stonehaven AB39 2DQ | 2.15 To provide new school building. | The proposed permanent single storey detached building is 148 m ² . The existing care office / accommodation building is sprinklered. The existing school buildings total 816 m ² . | Granted |
| 2013/39 | 13/08/2013 | Sunflower Nursery Melgund Place Lochgelly Fife KY5 9QY | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Kingdom House Kingdom Avenue Glenrothes KY7 5LY | 2.15 To provide extension to existing nursery. | The proposed extension is 137 m ² . The existing nursery is 261 m ² . The existing nursery is not sprinklered and in the extension is under 500 m ² . | Granted |
| 2013/40 | 13/08/2013 | Balcurvie School Balcurvie Road Windygates Leven Fife KY8 5DY | School | [redacted] Service Manager Fife Council Enterprise and Protective Services Kingdom House Kingdom Avenue Glenrothes KY7 5LY | 2.15 The proposed extension is to provide a new staff room and gym hall store. | The proposed Extension is 38 m ² . The main school building is 888 m ² . | Granted |

| | | | | | | | |
|---------|---|--|--------|--|--|--|---------|
| 2013/41 | 5/8/2013 Application Received 10 October 2013 by email. Original by post not received. | Lochnell Primary School Lochnell Ledaig Connel P37 1QS | School | [redacted] Building Standards Manager Argyll and Bute Council Development and Infrastructure Services Blairvadch Shandon By Helensburgh G84 8ND | 2.15 To Increase classbase size. | The proposed extension is 34 m ² . Cost of sprinklers is disproportionate to extension cost. | Granted |
| 2013/43 | 24/10/2013 | Alvie Primary School Alvie Kincraie Kingussie PH21 1ND | School | [redacted] Building Standards Manager The Highland Council Planning and Building Standards Service Council Headquarters Glenurquart Road Inverness IVR 5NX | 2.15 The proposed single storey extension to the main school building will provide toilets, a cloakroom, a cleaner's room, a store and a link corridor. | The extension is approximately 68 m ² . Consider sprinklers disproportionate to cost. | Granted |

**NO FURTHER APPLICATIONS
RECEIVED TO DATE (9 JULY 2018)**