

**From:** <redacted>

**Sent:** 20 March 2023 15:22

**To:** DC <[dc@renfrewshire.gov.uk](mailto:dc@renfrewshire.gov.uk)>; [planning.sw@sepa.org.uk](mailto:planning.sw@sepa.org.uk); [strathclyde\\_ayrshire@nature.scot](mailto:strathclyde_ayrshire@nature.scot); [HMConsultations@hes.scot](mailto:HMConsultations@hes.scot); [centralscotland.cons@forestry.gov.scot](mailto:centralscotland.cons@forestry.gov.scot); <redacted>@forestry.gov.scot; [info@scotways.com](mailto:info@scotways.com); [scotland.planning@rspb.org.uk](mailto:scotland.planning@rspb.org.uk); <redacted>@scottishwildlifetrust.org.uk<redacted>; [assetprotection@nationalgrid.com](mailto:assetprotection@nationalgrid.com); [campaiging@woodlandtrust.org.uk](mailto:campaiging@woodlandtrust.org.uk); [TheCoalAuthority-Planning@coal.gov.uk](mailto:TheCoalAuthority-Planning@coal.gov.uk); <redacted>@glasgow.gov.uk; [Transmission.ple@sse.com](mailto:Transmission.ple@sse.com)<redacted>@transport.gov.scot; [PlanningConsultations@scottishwater.co.uk](mailto:PlanningConsultations@scottishwater.co.uk); [community.council.linwood@gmail.com](mailto:community.council.linwood@gmail.com); [W.ERRICSEnforcement@firescotland.gov.uk](mailto:W.ERRICSEnforcement@firescotland.gov.uk); [HazSubCon.CEMHD5@hse.gov.uk](mailto:HazSubCon.CEMHD5@hse.gov.uk)

**Cc:** <redacted>@erm.com

**Subject:** Electricity Act 1989: Linwood Battery Energy Storage System, Renfrewshire Council

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **THE ELECTRICITY (APPLICATIONS FOR CONSENT) REGULATIONS 1990**

#### **INSTALLATION OF A BATTERY ENERGY STORAGE SYSTEM AND ASSOCIATED INFRASTRUCTURE AND A CABLE ROUTE WITH A GENERATING CAPACITY OF UP TO 69 MW ON REDUNDANT LAND WITHIN AN EXISTING SCOTTISH WATER WASTEWATER/SEWAGE TREATMENT WORKS (“WTW”) LOCATED ON THE OUTSKIRTS OF LINWOOD, 22 KILOMETRES (“KM”) WEST OF GLASGOW AND 2.5KM WEST OF PAISLEY, IN THE PLANNING AUTHORITY AREA OF RENFREWSHIRE COUNCIL (“LINWOOD BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 20 February 2023, Bluestone Energy Ltd submitted an application under section 36 of the Electricity Act 1989 (“the Act”) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. Your organisation has been identified as a consultee. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The application is referred to as “Linwood Battery Energy Storage System” and the application documents are published on the Scottish Government’s Energy Consents Unit website at the following link:

<https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00004543>

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of 28 days from the date of this email for all other consultees. Additional days have been added to this period for the upcoming Public Holidays in April and May.

- **The Planning Authority, Renfrewshire Council**, has been given a period of 4 months (as well as 6 additional days allowing for Public Holidays) from the date of this email to respond to this consultation and **has until Wednesday 26 July 2023** to respond.
- **All other consultees have until Wednesday 19 April 2023** to respond.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it will be assumed you have no comments to make.

Please email your response to [Econsents\\_Admin@gov.scot](mailto:Econsents_Admin@gov.scot) (please note the underscore in the email address).

I look forward to receiving your response in due course.

Kind regards,

<redacted>

<redacted> | **Senior Case Officer | Energy Consents Unit**

Directorate for Energy and Climate Change | The Scottish Government | 5 Atlantic Quay, 150 Broomielaw, Glasgow G2 8LU | M: <redacted>

To view our current casework please visit [www.energyconsents.scot](http://www.energyconsents.scot)

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <http://www.energyconsents.scot/Documentation.aspx>

The [draft Energy Strategy and Just Transition Plan](#) is open for consultation until 9 May 2023:

**Tell us your views [here](#).**



**From:** <redacted>

**Sent:** Thursday, April 6, 2023 12:45 PM

**To:** 'planning.se@sepa.org.uk' <planning.se@sepa.org.uk>; 'forth@nature.scot' <forth@nature.scot>; 'HMConsultations@hes.scot' (HMConsultations@hes.scot) <HMConsultations@hes.scot>; 'southscotland.cons@forestry.gov.scot' <southscotland.cons@forestry.gov.scot>; <redacted><<redacted>@transport.gov.scot>; 'radionetworksprotection@bt.com' <radionetworksprotection@bt.com>; 'natssafeguarding@nats.co.uk' <natssafeguarding@nats.co.uk>; 'ONR-Land-Use-Planning@onr.gov.uk' <ONR-Land-Use-Planning@onr.gov.uk>; 'scotland.planning@rspb.org.uk' <scotland.planning@rspb.org.uk>; 'info@scotways.com' <info@scotways.com>; 'PlanningConsultations@scottishwater.co.uk' <PlanningConsultations@scottishwater.co.uk>; 'info@elcc.scot' <info@elcc.scot>; '<redacted>@scottishwildlifetrust.org.uk' <<redacted>@scottishwildlifetrust.org.uk>; '<redacted>@fms.scot' <brian@fms.scot>; 'TownPlanningScotland@networkrail.co.uk' <TownPlanningScotland@networkrail.co.uk>; 'E.MELBFSE@firescotland.gov.uk' <E.MELBFSE@firescotland.gov.uk>; 'HazSubCon.CEMHD5@hse.gov.uk' <HazSubCon.CEMHD5@hse.gov.uk>; 'TheCoalAuthority-Planning@coal.gov.uk' <TheCoalAuthority-Planning@coal.gov.uk>; <redacted>crownestatescotland.com' <<redacted>@crownestatescotland.com>

**Cc:** <redacted>gridcodepower.com' <<redacted>@gridcodepower.com>; Econsents Admin <Econsents\_Admin@gov.scot>

**Subject:** Electricity Act 1989 section 36 - consultation - application for consent to construct and operate Branxton Battery Energy Storage System

## **ELECTRICITY ACT 1989**

## **ELECTRICITY (APPLICATIONS FOR CONSENT) REGULATIONS 1990**

### **APPLICATION FOR CONSENT UNDER SECTION 36 OF THE ELECTRICITY ACT 1989 FOR CONSTRUCTION AND OPERATION OF BRANXTON BATTERY ENERGY STORAGE SYSTEM WITHIN THE PLANNING AUTHORITY AREA OF EAST LOTHIAN COUNCIL**

On 17 November 2022, EastcoastGridServices Ltd submitted an application under section 36 of the Electricity Act 1989 for the Scottish Ministers' consent to construct and operate a Battery Energy Storage System on land near Thorntonloch approximately 2.5 kilometres (km) east of Innerwick, at National Grid Reference ('NGR') 374768, 673428.

On 28<sup>th</sup> March 2023, the Scottish Ministers adopted the opinion that the proposed development is not EIA development.

In accordance with the Electricity (Applications for Consent) Regulations 1990, details of the application have been published in the national and local press.

### **Consultation**

The Electricity (Applications for Consent) Regulations 1990 allow 28 days for responses to this consultation. The Scottish Ministers wish to consult you on the proposal for your interests. I would be grateful for your response by **4<sup>th</sup> May 2023**.

The application documentation can be viewed at  
<http://branxtonenergystorage.com/planning-documents/>

Or accessed via the Scottish Government's Energy Consents Unit website,  
[www.energyconsents.scot](http://www.energyconsents.scot) by:

- clicking on **Search** tab; then,
- clicking on **Simple Search** tab; then,
- typing **Branxton** into **Search by Project Name** box then clicking on **Go**;
- then clicking on **ECU00004659** and then click on **Documents** tab.

Should you have any difficulties accessing the documents or if you require copies in a specific format please let me know as soon as possible.

**Please submit your response by email to [EconsentsAdmin@gov.scot](mailto:EconsentsAdmin@gov.scot)**

Please note reminders are not issued by Energy Consents, therefore if we have not received your comments, nor have we received any extension request by 4<sup>th</sup> May 2023, we will assume you have no comments to make.

Regards

<redacted> | **Team Leader | Energy Consents Unit**

Scottish Government | 4<sup>th</sup> Floor, 5 Atlantic Quay | 150 Broomielaw | Glasgow, G2 8LU

<redacted> To view our current casework please visit [www.energyconsents.scot](http://www.energyconsents.scot)



**From:** <redacted>

**Sent:** Friday, February 3, 2023 11:58 AM

**To:** 'developmentmanagement@pkc.gov.uk' <developmentmanagement@pkc.gov.uk>; 'planning.se@sepa.org.uk' <planning.se@sepa.org.uk>; 'tayside\_Grampian@nature.scot' <tayside\_Grampian@nature.scot>; 'HMConsultations@hes.scot' <HMConsultations@hes.scot>; <redacted><<redacted>@transport.gov.scot>; <redacted>@forestry.gov.scot' <<redacted>@forestry.gov.scot>; 'radionetworkprotection@bt.com' <radionetworkprotection@bt.com>; 'scotland.planning@rspb.org.uk' <scotland.planning@rspb.org.uk>; 'info@scotways.com' <info@scotways.com>; 'PlanningConsultations@scottishwater.co.uk' <PlanningConsultations@scottishwater.co.uk>; 'bwilson@scottishwildlifetrust.org.uk' <<redacted>@scottishwildlifetrust.org.uk>; 'info@visitscotland.com' <info@visitscotland.com>; 'assetprotection@nationalgrid.com' <assetprotection@nationalgrid.com>; 'HazSubCon.CEMHD5@hse.gov.uk' <HazSubCon.CEMHD5@hse.gov.uk>; 'alythcc@gmail.com' <alythcc@gmail.com>; 'meigleardlercc@gmail.com' <meigleardlercc@gmail.com>; <redacted>@firescotland.gov.uk' <<redacted>@firescotland.gov.uk>; 'Transmission.Asset.Management@sse.com' <Transmission.Asset.Management@sse.com>

**Cc:** <redacted><ae.associates@btinternet.com>

**Subject:** Electricity Act 1989: Alyth Battery Energy Storage System, Perth and Kinross Council

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **THE ELECTRICITY (APPLICATIONS FOR CONSENT) REGULATIONS 1990**

#### **INSTALLATION OF A BATTERY ENERGY STORAGE SYSTEM AND ASSOCIATED INFRASTRUCTURE WITH A GENERATING CAPACITY OF UP TO 450MW AT LAND LOCATED AT HAUGHEND FARM, BY MEIGLE, PERTSHIRE PH12 8RJ IN THE PLANNING AUTHORITY AREA OF PERTH AND KINROSS COUNCIL (“ALYTH BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 9 December 2022, AE Associates submitted an application on behalf of EcoDev (Alyth) Ltd, under section 36 of the Electricity Act 1989 (“the Act”) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. Your organisation has been identified as a consultee. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The application is referred to as “Alyth Battery Energy Storage System” and the application documents are published on the Scottish Government’s Energy Consents Unit website at the following link:

<https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00004631>

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this

consultation and serve notice of an objection, and a period of 28 days from the date of this email for all other consultees.

- **The Planning Authority, Perth and Kinross Council**, has been given a period of 4 months from the date of this email to respond to this consultation and **has until 6 June 2023** to respond.
- **All other consultees have until 3 March 2022** to respond.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it will be assumed you have no comments to make.

Please email your response to [Econsents\\_Admin@gov.scot](mailto:Econsents_Admin@gov.scot) (please note the underscore in the email address) FAO of <redacted>

I look forward to receiving your response in due course.

Kind regards,  
<redacted>

<redacted> (she/her) | **Senior Case Officer | Energy Consents Unit**  
Directorate for Energy and Climate Change | The Scottish Government | 5 Atlantic Quay, 150  
Broomielaw, Glasgow G2 8LU | M<redacted>

To view our current casework please visit [www.energyconsents.scot](http://www.energyconsents.scot)  
To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <http://www.energyconsents.scot/Documentation.aspx>

**From:** <redacted>On Behalf Of Econsents Admin

**Sent:** Wednesday, June 7, 2023 10:20 AM

**To:** 'dc@renfrewshire.gov.uk' <dc@renfrewshire.gov.uk>; 'planning.sw@sepa.org.uk' <planning.sw@sepa.org.uk>; 'strathclyde\_ayrshire@nature.scot' <strathclyde\_ayrshire@nature.scot>; 'HMConsultations@hes.scot' <HMConsultations@hes.scot>; 'scotland.planning@rspb.org.uk' <scotland.planning@rspb.org.uk>; '<redacted>@scottishwildlifetrust.org.uk' <<redacted>@scottishwildlifetrust.org.uk>; 'TheCoalAuthority-Planning@coal.gov.uk' <TheCoalAuthority-Planning@coal.gov.uk>; '<redacted>@glasgow.gov.uk' <<redacted>@glasgow.gov.uk>; '<redacted>'; 'PlanningConsultations@scottishwater.co.uk' <PlanningConsultations@scottishwater.co.uk>; 'secretary@paisleyeast.org' <secretary@paisleyeast.org>; 'W.ERRICSEnforcement@firescotland.gov.uk' <W.ERRICSEnforcement@firescotland.gov.uk>; 'HazSubCon.CEMHD5@hse.gov.uk' <HazSubCon.CEMHD5@hse.gov.uk>

**Subject:** Electricity Act 1989: application for consent for Stanely Water Battery Energy Storage System Application ref ECU00004544

Dear consultee

## ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION

ECU00004544 / STANELY WATER BATTERY ENERGY STORAGE SYSTEM AND ASSOCIATED INFRASTRUCTURE ON LAND WITHIN AN EXISTING SCOTTISH WATER WASTEWATER TREATMENT WORKS (WTW) LOCATED APPROXIMATELY 2.3 KILOMETRES (KM) SOUTH-WEST OF THE CENTRE OF PAISLEY AND 10 KM SOUTH-WEST OF THE CENTRE OF GLASGOW

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 23 March 2023, Bluestone Energy Ltd (Company Number 11673645) submitted an application under section 36 of the Electricity Act 1989 ('the Act') for the Scottish Ministers' consent to construct and operate the proposed electricity generating station described above, in the Renfrewshire Council planning authority area. The application also asks Scottish Ministers to make a direction that planning permission for the proposed development is deemed to be granted. Your organisation has been identified as a consultee.

The application is referred to as "Stanely Water Battery Energy Storage System" and the application documents are published on the Scottish Government Energy Consents website at

<https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00004544>. Details of the application will also be published by the Company in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of 28 days from the date of this email for all other consultees.

- The Planning Authority, Renfrewshire Council, has been given a period of 4 months from the date of this email to respond to this consultation and has until 7 October 2023 to respond.
- All other consultees have until 5 July 2023 to respond.

Please send your response to [EconsentsAdmin@gov.scot](mailto:EconsentsAdmin@gov.scot). If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it will be assumed you have no comments to make.

I look forward to receiving your response in due course.

Yours faithfully

<redacted>

<redacted> | **Onshore Electricity Policy, Strategic Co-ordination & Consents Division**  
Directorate for Energy and Climate Change | Scottish Government | 5 Atlantic Quay, 150 Broomielaw,  
Glasgow G2 8LU

I work as one of the case officers in the Energy Consents Unit of the Scottish Government and my job is to process applications for electricity generating stations which are not dealt with by our teams of dedicated wind farm or electricity grid specialists.

To view our current casework please visit <https://www.energyconsents.scot>

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <https://www.energyconsents.scot/Documentation.aspx>

If you are dissatisfied with our service, please tell us. We will work with you to resolve it. Please see <https://www.gov.scot/about/contact-information/make-a-complaint/>



**From:** <redacted>

**Sent:** Monday, October 31, 2022 12:21 PM

**To:** 'esplanning@northlan.gov.uk' <esplanning@northlan.gov.uk>; 'planningenquiry@glasgow.gov.uk' <planningenquiry@glasgow.gov.uk>; 'planning.sw@sepa.org.uk' <planning.sw@sepa.org.uk>; 'HMConsultations@hes.scot' <HMConsultations@hes.scot>; <redacted>@nature.scot' <<redacted>@nature.scot>; 'strathclyde\_ayrshire@nature.scot' <strathclyde\_ayrshire@nature.scot>; <redacted><<redacted>@transport.gov.scot>; 'scotland.planning@rspb.org.uk' <scotland.planning@rspb.org.uk>; 'info@scotways.com' <info@scotways.com>; 'PlanningConsultations@scottishwater.co.uk' <PlanningConsultations@scottishwater.co.uk>; '<redacted>@scottishwildlifetrust.org.uk' <<redacted>@scottishwildlifetrust.org.uk>; <redacted>@glasgow.gov.uk' <<redacted>@glasgow.gov.uk>; 'TheCoalAuthority-Planning@coal.gov.uk' <TheCoalAuthority-Planning@coal.gov.uk>; 'AssetProtectionScotland@networkrail.co.uk' <AssetProtectionScotland@networkrail.co.uk>; 'W.GLAComsEnforcement@firescotland.gov.uk' <W.GLAComsEnforcement@firescotland.gov.uk>; 'W.NLCommunitySafety@firescotland.gov.uk' <W.NLCommunitySafety@firescotland.gov.uk>; 'HazSubCon.CEMHD5@hse.gov.uk' <HazSubCon.CEMHD5@hse.gov.uk>; <redacted>@spenergynetworks.co.uk' <<redacted>@spenergynetworks.co.uk>; 'PlantProtectionAndPipelinesNorth@sgn.co.uk' <PlantProtectionAndPipelinesNorth@sgn.co.uk>; <redacted>@sgn.co.uk' <<redacted>@sgn.co.uk>; 'lupenquiries@hsl.gsi.gov.uk' <lupenquiries@hsl.gsi.gov.uk>

**Cc:** <redacted><<redacted>@loganpm.co.uk>; Econsents Admin <Econsents\_Admin@gov.scot>

**Subject:** Electricity Act 1989: Whitehill Energy Storage, North Lanarkshire Council and Glasgow City Council

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **THE ELECTRICITY (APPLICATIONS FOR CONSENT) REGULATIONS 1990**

#### **INSTALLATION OF A BATTERY ENERGY STORAGE FACILITY AND ASSOCIATED ACCESS AND INFRASTRUCTURE WITH A GENERATING CAPACITY OF AROUND 200MW AT WHITEHILL FARM BY GARTCOSH, G69 8DT, TO BE LOCATED IN THE PLANNING AUTHORITY AREAS OF NORTH LANARKSHIRE COUNCIL AND GLASGOW CITY COUNCIL (“WHITEHILL ENERGY STORAGE”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 10 October 2022, Intelligent Land Investments Group plc submitted an application under section 36 of the Electricity Act 1989 (“the Act”) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. Your organisation has been identified as a consultee. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The application is referred to as “Whitehill Energy Storage” and the application documents are published on the Scottish Government’s Energy Consents Unit website [www.energyconsents.scot](http://www.energyconsents.scot) by:

- clicking on **Search** tab; then,
- clicking on **Simple Search** tab; then,
- typing *Whitehill Energy Storage* into **Search by Project Name** box then clicking on **Go**;
- then clicking on **EC00004632** and then click on Documents tab.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of 28 days from the date of this email for all other consultees.

- **The Planning Authorities, North Lanarkshire Council and Glasgow City Council**, has been given a period of 4 months from the date of this email to respond to this consultation and **have until Tuesday 14 March 2023** to respond.  
\* Please note 2 weeks have been added to this consultation period to allow for the Christmas period \*
- **All other consultees** have until **Monday 28 November 2022** to respond.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it will be assumed you have no comments to make.

Please email your response to [Econsents\\_Admin@gov.scot](mailto:Econsents_Admin@gov.scot) (please note the underscore in the email address) FAO of <redacted>

I look forward to receiving your response in due course.

Kind regards,

<redacted>

<redacted> | **Senior Case Officer | Energy Consents Unit**

Directorate for Energy and Climate Change | The Scottish Government | 5 Atlantic Quay, 150 Broomielaw, Glasgow G2 8LU | M<redacted>

To view our current casework please visit [www.energyconsents.scot](http://www.energyconsents.scot)

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <http://www.energyconsents.scot/Documentation.aspx>

**From:** <redacted>

**Sent:** Friday, December 9, 2022 10:37 AM

**Subject:** Electricity Act 1989: Camsiscan Farm Battery Energy Storage System, South Ayrshire Council

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **THE ELECTRICITY (APPLICATIONS FOR CONSENT) REGULATIONS 1990**

#### **INSTALLATION OF A BATTERY ENERGY STORAGE SYSTEM AND ASSOCIATED INFRASTRUCTURE WITH A GENERATING CAPACITY OF UP TO 350MW AT LAND AT CAMSISCAN FARM, CRAIGIE, KILMARNOCK SOUTH, SOUTH AYRSHIRE, KA1 5JT (“CAMSISCAN FARM BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 05 December 2022, Scott Hobbs Planning submitted an application on behalf of Scot Stability Ltd, under section 36 of the Electricity Act 1989 (‘the Act’) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. Your organisation has been identified as a consultee. Details of the application will also be published in the press and in the Ayr Advertiser, Edinburgh Gazette and Herald to inform the general public how they may make representations to the Scottish Ministers on the application.

The application is referred to as “Camsiscan Farm Battery Energy Storage System” and the application documents are published on the Scottish Government’s Energy Consents Unit website [www.energyconsents.scot](http://www.energyconsents.scot) by:

- clicking on **Search** tab; then,
- clicking on **Simple Search** tab; then,
- typing **Land at Camsiscan Farm 350MW** into **Search by Project Name** box then clicking on **Go**;
- then clicking on **EC00004658** and then click on Documents tab.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of 28 days from the date of this email for all other consultees.

- **The Planning Authorities, South Ayrshire Council**, has been given a period of 4 months from the date of this email to respond to this consultation and **has until Tuesday 18 April 2023** to respond.
- **All other consultees have until Monday 16 January 2023** to respond.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it will be assumed you have no comments to make.

Please email your response to [Econsents\\_Admin@gov.scot](mailto:Econsents_Admin@gov.scot) (please note the underscore in the email address) FAO of <redacted>.

I look forward to receiving your response in due course.

Kind regards,

<redacted> **Consents Caseworker | Energy Consents Unit | The Scottish Government**

**Email:** <redacted>



**From:** <redacted>

**Sent:** Wednesday, November 22, 2023 9:15 AM

**Subject:** Electricity Act 1989: application under section 36 - Kilmarnock 500 MW Battery Energy Storage System located approximately 250 m north of Kilmarnock South Substation ("KSS")

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **ELECTRICITY GENERATING STATION AND ASSOCIATED INFRASTRUCTURE ON LAND APPROXIMATELY 250 METRES NORTH OF KILMARNOCK SOUTH SUBSTATION ("KSS")("KILMARNOCK 500MW BATTERY ENERGY STORAGE SYSTEM")**

I work in the Energy Consents Unit of the Scottish Government, and I am contacting you in relation to the above application, as I am the case officer. On 03 October 2023, AECOM on behalf of Kilmarnock Energy Centre Limited (Company Number SC766862) submitted an application under section 36 of the Electricity Act 1989 ('the Act') for the Scottish Ministers' consent to construct and operate the proposed electricity generating station described above. The application also asks Scottish Ministers to make a direction that planning permission for the proposed development is deemed to be granted. Your organisation has been identified as a consultee.

The application is referred to as "Kilmarnock 500 MW Battery Energy Storage System" and the application documents are published on the Scottish Government Energy Consents website at [Scottish Government - Energy Consents Unit - Application Details](#) – **ECU00004941**. Details of the application were also published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of at 28 days from the date of this email for all other consultees.

- The Planning Authority, Aberdeenshire Council, has been given a period of 4 months from the date of this email to respond to this consultation and has until **22 March 2024** to respond.
- All other consultees have until **21 December 2023** to respond.

**If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it may be assumed you have no comments to make.**

I look forward to receiving your response in due course.

Kind regards

<redacted>

<redacted> **Case Officer, Onshore Electricity, Strategy and Consents**

**Directorate for Energy and Climate Change | Scottish Government | 5 Atlantic Quay, 150 Broomielaw,  
Glasgow G2 8LU**

**e-mail:** <redacted>

**From:** <redacted>On Behalf Of Econsents Admin

**Sent:** 22 August 2023 17:57

**To:** Econsents Admin <[Econsents\\_Admin@gov.scot](mailto:Econsents_Admin@gov.scot)>

**Subject:** Electricity Act 1989: application under section 36 - Carlisle Road Battery Energy Storage System near Coalburn, South Lanarkshire

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **ELECTRICITY GENERATING STATION AND ASSOCIATED INFRASTRUCTURE ON LAND ADJACENT TO CARLISLE ROAD (B7078) AT COALBURN, SOUTH LANARKSHIRE (“CARLISLE ROAD BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer. On 7 June 2023, Zenobe Energy Limited (Company Number 10436249) submitted an application under section 36 of the Electricity Act 1989 (‘the Act’) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. The application also asks Scottish Ministers to make a direction that planning permission for the proposed development is deemed to be granted. Your organisation has been identified as a consultee.

The application is referred to as “Carlisle Road Battery Energy Storage System” and the application documents are published on the Scottish Government Energy Consents website at

<https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00004799>. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of at 28 days from the date of this email for all other consultees.

- The Planning Authority, South Lanarkshire Council, has been given a period of 4 months from the date of this email to respond to this consultation and has until 23 December 2023 to respond.
- All other consultees have until 27 September 2023 to respond.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it may be assumed you have no comments to make.

I look forward to receiving your response in due course.

Yours faithfully

<redacted>

<redacted>| **Onshore Electricity Policy, Strategic Co-ordination & Consents Division**

Directorate for Energy and Climate Change | Scottish Government | 5 Atlantic Quay, 150 Broomielaw,  
Glasgow G2 8LU

I work as one of the case officers in the Energy Consents Unit of the Scottish Government and my job is to process applications for electricity generating stations which are not dealt with by our teams of dedicated wind farm or electricity grid specialists.

To view our current casework please visit <https://www.energyconsents.scot>

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <https://www.energyconsents.scot/Documentation.aspx>

If you are dissatisfied with our service, please tell us. We will work with you to resolve it. Please see <https://www.gov.scot/about/contact-information/make-a-complaint/>



**From:** <redacted>

**Sent:** Monday, June 17, 2024 11:48 AM

**To:** Econsents Admin <Econsents\_Admin@gov.scot>

**Subject:** RE: Electricity Act 1989: application under section 36 - Shetland Battery Energy Storage System at Lerwick

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **ELECTRICITY GENERATING STATION AND ASSOCIATED INFRASTRUCTURE ON LAND NORTH OF PERSLEY WASTEWATER TREATMENT PLANT, ABERDEEN (“PERSLEY BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer assigned to deal with the consultation on it. On 6 June 2024, Anesco Ltd, (company registration number 07443091), with its registered office at, The Green, Easter Park, Benyon Road, Reading, Berkshire, RG7 2PQ submitted an application under section 36 of the Electricity Act 1989 (‘the Act’) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. The application also asks Scottish Ministers to make a direction that planning permission for the proposed development is deemed to be granted. Your organisation has been identified as a consultee on the application.

The application is referred to as “Persley Battery Energy Storage System” and the application documents are published on the Scottish Government Energy Consents website at <https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00005113>. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of at 28 days from the date of this email for all other consultees.

- **The Planning Authority, Aberdeen City Council, has been given a period of 4 months** from the date of the application to respond to this consultation and has until 6 October 2024 to respond. The Planning Authority should make arrangements for the application documents to be placed on the planning register and made available for inspection by the public. It is the developer’s responsibility to send these to you.
- **All other consultees have until 16 July 2023 to respond.**

Please submit your response by email to [EconsentsAdmin@gov.scot](mailto:EconsentsAdmin@gov.scot) or contact me directly if you have any queries.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it may be assumed you have no comments to make.

I look forward to receiving your response in due course.

Yours faithfully

<redacted>

<redacted>| **Onshore Electricity Policy, Strategic Co-ordination & Consents Division**  
Directorate for Energy and Climate Change | Scottish Government | 5 Atlantic Quay, 150 Broomielaw,  
Glasgow G2 8LU

I work as one of the case officers in the Energy Consents Unit of the Scottish Government and my job is to process applications for electricity generating stations which are not dealt with by our teams of dedicated wind farm or electricity grid specialists.

To view our current casework please visit <https://www.energyconsents.scot>

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <https://www.energyconsents.scot/Documentation.aspx>

If you are dissatisfied with our service, please tell us. We will work with you to resolve it. Please see <https://www.gov.scot/about/contact-information/make-a-complaint/>

**From:** <redacted>

**Sent:** Monday, June 17, 2024 11:48 AM

**To:** Econsents Admin <Econsents\_Admin@gov.scot>

**Subject:** RE: Electricity Act 1989: application under section 36 - Shetland Battery Energy Storage System at Lerwick

Dear consultee

## **ELECTRICITY ACT 1989 - APPLICATION TO CONSTRUCT AND OPERATE AN ELECTRICITY GENERATING STATION**

### **ELECTRICITY GENERATING STATION AND ASSOCIATED INFRASTRUCTURE ON LAND NORTH OF PERSLEY WASTEWATER TREATMENT PLANT, ABERDEEN (“PERSLEY BATTERY ENERGY STORAGE SYSTEM”)**

I work in the Energy Consents Unit of the Scottish Government and I am contacting you in relation to the above application, as I am the case officer assigned to deal with the consultation on it. On 6 June 2024, Anesco Ltd, (company registration number 07443091), with its registered office at, The Green, Easter Park, Benyon Road, Reading, Berkshire, RG7 2PQ submitted an application under section 36 of the Electricity Act 1989 (‘the Act’) for the Scottish Ministers’ consent to construct and operate the proposed electricity generating station described above. The application also asks Scottish Ministers to make a direction that planning permission for the proposed development is deemed to be granted. Your organisation has been identified as a consultee on the application.

The application is referred to as “Persley Battery Energy Storage System” and the application documents are published on the Scottish Government Energy Consents website at <https://www.energyconsents.scot/ApplicationDetails.aspx?cr=ECU00005113>. Details of the application will also be published in the press and in the Edinburgh Gazette to inform the general public how they may make representations to the Scottish Ministers on the application.

The Electricity (Applications for Consent) Regulations 1990 allow a period of 4 months from the date of the application for the Planning Authority to respond to this consultation and serve notice of an objection, and a period of at 28 days from the date of this email for all other consultees.

- **The Planning Authority, Aberdeen City Council, has been given a period of 4 months** from the date of the application to respond to this consultation and has until 6 October 2024 to respond. The Planning Authority should make arrangements for the application documents to be placed on the planning register and made available for inspection by the public. It is the developer’s responsibility to send these to you.
- **All other consultees have until 16 July 2023 to respond.**

Please submit your response by email to [EconsentsAdmin@gov.scot](mailto:EconsentsAdmin@gov.scot) or contact me directly if you have any queries.

If the Scottish Government has not received your comments, nor received any extension request by the relevant date indicated above, it may be assumed you have no comments to make.

I look forward to receiving your response in due course.

Yours faithfully

<redacted>

<redacted> | **Onshore Electricity Policy, Strategic Co-ordination & Consents Division**  
Directorate for Energy and Climate Change | Scottish Government | 5 Atlantic Quay, 150 Broomielaw,  
Glasgow G2 8LU

I work as one of the case officers in the Energy Consents Unit of the Scottish Government and my job is to process applications for electricity generating stations which are not dealt with by our teams of dedicated wind farm or electricity grid specialists.

To view our current casework please visit <https://www.energyconsents.scot>

To read the Energy Consents Unit's privacy notice on how personal information is used, please visit <https://www.energyconsents.scot/Documentation.aspx>

If you are dissatisfied with our service, please tell us. We will work with you to resolve it. Please see <https://www.gov.scot/about/contact-information/make-a-complaint/>

From: <redacted>  
To: Econsents Admin  
Cc: <redacted><redacted>  
Subject: FAO <redacted>- Alyth Battery Energy Storage System  
Date: 09 February 2023 13:34:42  
Attachments: image001.png

Good afternoon <redacted>,

In respect of the proposed Alyth Battery Energy Storage System, having reviewed the proposal documents, I have no adverse concerns. There is clear fire safety arrangements detailed within the preliminary construction environment management plan. This also details an inert gas suppression system as well as a water mist deluge system which are built into the design to ensure the risk is managed. It would however, be advantageous for local SFRS crews to have an additional water supply in order to supplement the water that is carried on appliances.

Best regards, <redacted>

<redacted> | Watch Commander | Fire Safety Enforcement Officer - Angus | Arbroath Community Fire Station | Arbroath | DD11 1EU | Scottish Fire and Rescue Service | <redacted> |  
[E<redacted>@firescotland.gov.uk](mailto:E<redacted>@firescotland.gov.uk)

E-mail confidentiality notice The information contained in this message is confidential and intended for the addressee only. The unauthorised use, disclosure, copying or alteration of this message is prohibited. If you have received this e-mail in error, please reply to the sender immediately and delete the message

From: N PKAD Fire Safety Enforcement Officers  
To: <redacted>  
Subject: RE: Electricity Act 1989: Balnuith BESS, Angus Council  
Date: 13 December 2023 15:24:49  
Attachments: image002.png image003.png

Good afternoon, In relation to the below application, the Scottish Fire and Rescue Service notes the intended provision of automatic suppression systems within the site. It would be prudent however, to install a pressurised hydrant, or an alternative water supply to aid fire crews with extinguishing any potential fires in a timely manner.

Best regards, <redacted>

<redacted> | Watch Commander | Fire Safety Enforcement Officer - Angus | Arbroath Community Fire Station | Arbroath | DD11 1EU | Scottish Fire and Rescue Service | <redacted> | E: <redacted>@firescotland.gov.uk

From: SFRS Enforcement Centre

To: <redacted>

Cc: SFRS Enforcement Centre; SFRS Water Planning; E MELB Fire Safety Enforcement

Subject: FW: PITTLESHEUGH BATTERY ENERGY STORAGE PROJECT ECU00004872

Date: 22 April 2024 10:16:40

Good morning,

Thank you for your email.

There is currently no statutory requirement for Fire and Rescue Services (FRSs) to engage in the planning process of BESS sites. However, The National Fire Chiefs Council (NFCC) encourages early engagement with the local FRS, continuing throughout the planning process, and have therefore provided a guidance document. This document relates specifically to grid scale BESS, in open air environments, using lithium-ion batteries.

This guidance does not seek to provide a full specification or opinion on the entirety of a BESS system design. Instead, the aim is to limit the content to such matters that directly relate to facilitating a safe and effective response, by the fire and rescue service, to a fire or vapour cloud release involving a BESS installation. This includes factors such as facilities for the fire and rescue service, and design factors that contribute to reducing the escalation in the severity of an incident.

With this in mind, your enquiry has been passed to our water planning department and local fire safety office for consideration/comment and they may reply, if required, in due course.

Any response from SFRS will follow the NFCC guidance and we would normally only make comment regarding access and water supplies with regards to planning applications.

In the meantime, please find attached a copy of the NFCC "Grid Scale Battery Energy Storage System planning – Guidance for FRS"

Kind regards,

<redacted>- Watch Commander | National Fire Safety Enforcement | Prevention & Protection  
Scottish Fire and Rescue Service | ESDA HQ, 28 Claylands Road, Newbridge | Edinburgh | EH28 8LF  
redacted E: <redacted>@firescotland.gov.uk | [SFRS.EnforcementCentre@firescotland.gov.u](mailto:SFRS.EnforcementCentre@firescotland.gov.uk)

From: N HLND Prevention and Protection Legislation Support

Sent: 24 October 2023 15:36

To: Econsents Admin Subject:

RE: Electricity Act 1989: application under section 36 - Shetland Battery Energy Storage System at Lerwick

Good Afternoon

SENT ON BEHALF OF FIRE SAFETY AUDITING OFFICER, <redacted>— SCOTTISH FIRE AND RESCUE SERVICE

The Scottish Fire and Rescue Service has no comments or objections regarding Shetland Battery Energy Storage System at Lerwick.

Kind regards,

<redacted>

<redacted> | SDA Business Support Assistant (Inverness) | Scottish Fire and Rescue Service T:

<redacted>, E: <redacted>@firescotland.gov.uk (Mon-Thurs 0845 – 1645 hrs, Fri 0845 – 1530 hrs)



From: <redacted>

Sent: 08 April 2022 11:25

To: <redacted>Cc: Econsents Admin; <redacted>

Subject: Electricity Act 1989 Application - Tealing Battery Energy Storage Farm

Hello <redacted>,

Thank you for the opportunity to make comment on the application for the proposed battery storage facility. My only comment would be the lack of water supplies for firefighting purposes with the nearest hydrants being located around 2km away. There was a fire at a similar site in Liverpool 2020 where the automatic suppression and alerting system both failed. The resultant fire required large amounts of water and several hours to extinguish it. It would be prudent to install a pressurised hydrant, or an alternative water supply to aid fire crews to extinguish any potential fires in a timely manner thus helping to save part of the facility.

Kind Regards

<redacted>

<redacted> | Fire Safety Enforcement Officer | Angus Scottish Fire and Rescue Service

<redacted><redacted>@firescotland.gov.uk